

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3550-1305:115 Page 1 of 1

CATEGORY: Door/Closer/holders/Releasing Devices

LISTEE: Corbin Russwin, 225 Episcopal Rd., Berlin CT 06037
Contact: Pradip Basu (860) 828-7377 *FAX (800) 659-7293

DESIGN: Series DC26900, sizes 2 through 6 are of the surface-mounted type that can be regular mounted, parallel arm mounted and top jamb mounted. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as door holders/closers when interconnected to separately listed compatible fire alarm control units and detection devices listed for releasing device service.

NOTE: 1. Formerly 3550-0522:017

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager